EMERGENCY GENERATOR TANK SYSTEM
UNBURIED PIPING EXEMPTION INSPECTION LOG

Per California Health and Safety Code, Chapter 6.7, §25281.5(b)(3), the operator of an emergency generator underground storage tank system must conduct visual inspections of unburied portions of fuel piping runs each time the fuel supply pump operates, but no less than monthly, in order to exempt the piping from being regulated piping per California Underground Storage Tank Regulations. A log of these daily inspections must be kept and made available for inspection.

Facility Name: _____

Date	Inspector Name	All Unburied Piping Is Visible and Unobstructed?	Pipe In Good Condition?	No Leaks Observed?	Comments/Corrective Actions
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Explain any problems found and corrective actions taken in the “Comments/Corrective Actions” section.
This log is part of the facility’s underground storage tank monitoring records and must be kept on-site for a minimum of three (3) years.